



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7270-1671:0104
<b>CATEGORY:</b>	7270 - HEAT DETECTOR
<b>LISTEE:</b>	ELK PRODUCTS, INC. 3266 Highway 70, Hildebran, NC, 28637 Contact: Burrell, Michael (828) 397-4200 Email: michael.burrell@elkproducts.com
<b>DESIGN:</b>	Model ELK-6053 Battery Operated Heat Detector with RF Transmitter, 135°F Fixed Temperature with 15°F/min Rate-of-Rise. Product utilizes wireless two-way communications which provides for the required interconnection of two or more detectors. Intended for residential applications.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	3 VDC  Battery Type Installed: Panasonic CR123A
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as a heat detector for use with listee's separately listed fire alarm control unit Model ELK-M1G (CSFM Listing No. 7167-1671:0101). Model complies with the applicable requirements in UL 521, 7th Edition. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

7-14-22 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/09/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division