



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7167-1671:0101
CATEGORY:	7167 - CONTROL UNIT (HOUSEHOLD)
LISTEE:	ELK PRODUCTS, INC. 3266 Highway 70, Hildebran, NC, 28637 Contact: Burrell, Michael (828) 397-4200 Email: michael.burrell@elkproducts.com
DESIGN:	<p>Model ELK-M1G combination household fire and burglary alarm control unit. Power-limited. Model ELK-M1G consists of Model ELK-M1GCB circuit board, Keypad Model ELK-M1KP and Elk Model ELK-SWB14, ELK-UB14, or ELK-SWB28 enclosures, or OnQ Models 363474-01, 363474-11, 363475-01, 363475-11, 364591-01, 364591-01, 364591-02, 364591-11, 363476-01, 363476-11, 364592-01, 364592-02, 364592-11 when used with Universal Mounting plate Model 364453 for mounting the ELK-M1GCB. Refer to listee's data sheet for additional detailed product description and operational considerations. System Components:</p> <p>ELK-M1XIN; Input Zone Expander</p> <p>ELK-M1XOVR; Output Zone Expander</p> <p>ELK-M1XOV; Output Voltage Expander</p> <p>ELK-M1RB; Output Relay Board</p> <p>*ELK-M1XRFTW; RF Transceiver/expander</p>
RATING:	<p>Primary: Class 2, 120 VAC, 16.5 VDC transformer</p> <p>Secondary: 12 VDC lead acid type battery</p>
INSTALLATION:	In accordance with listee's printed programming and installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical ratings and UL label.
APPROVAL:	Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

NOTES:

1. Fire Alarm Verification Feature (delay of fire alarm) is NOT approved for use in California. This feature shall not be programmed into the control unit.
2. Burglary and other non-fire functions were not examined.

*Rev 06-17-14 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/09/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division